

ORDINANCE NO. 75-4

AN ORDINANCE AMENDING HERNANDO COUNTY ORDINANCE NO. 71-5 BY ADDING AN ADDITIONAL REQUIREMENT PERTAINING TO SPRINKLER SYSTEMS; PROVIDING AN EFFECTIVE DATE

BE IT ORDAINED BY THE BOARD OF COUNTY COMMISSIONERS OF HERNANDO COUNTY, FLORIDA:


SECTION 1: Section 2 of Hernando County Ordinance No. 71-5 is hereby amended by adding to the standard contained in Section 120.54 of the Southern Standard Plumbing Code the requirement that all sprinkler systems installed within the County shall be installed at a minimum depth of twelve (12) inches below the ground surface.

SECTION 2: This Ordinance shall become effective as provided by law.

ADOPTED in Regular Session this 29<sup>th</sup> day of April, 1975.

ATTEST:

BOARD OF COUNTY COMMISSIONERS  
HERNANDO COUNTY, FLORIDA



HAROLD WILLIAM BROWN, CLERK



FRANK FISH, CHAIRMAN

Request permission to advertise for an addition to Ordinance #71-5 of the Plumbing Ordinance.

Sec. 2 - 7 Reserved

DIV. 2 - ADDITIONS TO SOUTHERN STANDARD PLUMBING CODE

- (a) Reference Section 1205.4 of the *Standard Plumbing Code* to include all sprinkler systems horizontally installed in Hernando County be a minimum of twelve (12) inches below ground surface.